

Addendum No-1


In continuation with the Tender Notice published in the news papers for Tender No. CE (Distribution)/Infra Plan-I/Mumbai/07-08, all the bidders are requested to note the following.

- Wedge connectors conforming to the specifications given in the bidding documents shall be used in the construction of LT/HT Lines & Substations up to the conductor size of 0.1 (DOG) in place of Binding & crimping mentioned in the price schedules.

The wedge connectors shall be used during construction for jumpers at cut points, T-connections & Vertical drops in DTCs

- For conductors of size 0.2 sq. inch crimping of all joints by compression method shall be used in construction as well as in sub stations.

All the Bidders are requested to take a note of above and shall quote their offers considering the above aspect. This addendum No-1 issued shall form part and parcel of the bidding documents. It is requested to enclose a signed copy of an Addendum No-1 along with submission of technical bids.


Chief Engineer (Distribution)